

Mid-Coast Council

PO Box 450

Forster NSW 2428

Cooperook Sewage Treatment Plant

Emmo Lane

Cooperook NSW 2426

Environmental Protection licence number: 12583

Licence anniversary date

16th April

Abbreviations-

TSS: Total Suspended Solids

BOD: Biochemical Oxygen Demand

EPA Monitoring Point 2, Discharge Quality Monitoring

Effluent Quality Monitoring Results

Monitoring frequency: monthly

Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms (cfu/100ml)	Oil & Grease (mg/L)	Compliance
3/05/2022	16/May/22	7.3	<2	<2	<2	<5	yes
7/06/2022	17/06/2022	7.4	<2	5	16	<5	yes
5/07/2022	19/07/2022	7.5	<2	2	2	<5	yes
2/08/2022	22/08/2022	7.6	3	<2	2	<5	yes
13/09/2022	20/09/2022	7.5	4	4	4	<5	yes
5/10/2022	21/10/2022	7.4	6	7	26	<5	yes
1/11/2022	21/11/2022	7.4	2	3	4	<5	yes
6/12/2022	21/12/2022	7.6	2	3	2	<5	yes
10/01/2023	24/01/2023	7.5	<2	2	~<4	<5	yes
7/02/2023	20/02/2023	7.6	4	2	8	<5	yes
7/03/2023	20/03/2023	7.6	16	<2	10	<5	yes
12/04/2023	21/04/2023	7.5	<2	<2	14	<5	yes
Concentration limits		100%ile	6.5-8.5	30	30	200	10
Annual summary							
	minimum	7.3	2	2	2	0	
	average	7.49	5.29	3.50	8.80	#DIV/0!	
	maximum	7.6	16	7	26	0	

Non-compliance comments: