

# Mid-Coast Council

PO Box 482

Taree NSW 2430

## Lansdowne Sewage Treatment Plant

Off Central Lansdowne Rd

Lansdowne NSW 2426

Environmental Protection licence number: 12586

Licence anniversary date

16th April

Abbreviations-

TSS: Total Suspended Solids

BOD: Biochemical Oxygen Demand

## EPA Monitoring Point 2,

### Discharge Quality Monitoring

Effluent Quality Monitoring Results							
Monitoring frequency: monthly							
Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms	Oil & Grease	Compliance
2/05/2023	25/05/2023	7.5	2	3	8	<5	yes
6/06/2023	20/06/2023	7.6	2	4	2	<5	yes
4/07/2023	18/07/2023	7.5	3	4	6	<5	yes
1/08/2023	17/08/2023	7.5	<2	<2	4	<3	yes
5/09/2023	5/10/2023	7.5	<2	3	6	<3	yes
4/10/2023	24/10/2023	7.5	<2	2	<2	<3	yes
7/11/2023	23/11/2023	7.4	4	3	<4	<3	yes
5/12/2023	12/12/2023	7.6	4	<2	<2	<3	yes
9/01/2024	25/01/2024	7.6	<2	<2	1	<3	yes
6/02/2024	16/02/2024	7.5	7	3	2	<3	yes
5/03/2024	19/03/2024	7.43	2	<2	<2	<3	yes
9/04/2024	22/04/2024	7.3	3	<2	8	<3	yes
Concentration limits		100%ile	6.5-8.5	30	30	200	10
<b>Annual summary</b>							
	minimum	7.30	2	2	1	<5	
	average	7.49	3.38	3.14	4.63	<5	
	maximum	7.6	7	4	8	<5	

**Non-compliance comments:**