

# Mid-Coast Council

PO Box 450

Forster NSW 2428

## Cooperook Sewage Treatment Plant

Emmo Lane

Cooperook NSW 2426

Environmental Protection licence number: 12583

Licence anniversary date

16th April

Abbreviations-

TSS: Total Suspended Solids

BOD: Biochemical Oxygen Demand

## EPA Monitoring Point 2, Discharge Quality Monitoring

### Effluent Quality Monitoring Results

Monitoring frequency: monthly

Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms (cfu/100ml)	Oil & Grease (mg/L)	Compliance
27/04/2021	13/May/21	7.4	2	2	2	<5	yes
25/05/2021	7/05/2021	7.4	2	2	4	<5	yes
22/06/2021	1/07/2021	7.4	6	4	4	<5	yes
20/07/2021	2/08/2021	7.5	<2	2	<2	<5	yes
17/08/2021	24/08/2021	7.6	2	2	48	<5	yes
14/09/2021	27/09/2021	7.6	2	<2	40	<5	yes
12/10/2021	21/10/2021	7.6	6	3	<4	<5	yes
9/11/2021	25/11/2021	7.5	2	2	<2	<5	yes
7/12/2021	21/12/2021	7.2	2	2	6	<5	yes
5/01/2022	19/01/2022	7.6	7	4	~4	<5	yes
1/02/2022	14/02/2022	7.4	2	<2	<2	<5	yes
1/03/2022	17/03/2022	7.3	3	<2	8	<5	yes
5/04/2022	27/04/2022	7.3	<2	<2	2	<5	yes

Concentration limits

100%ile

6.5-8.5

30

30

200

10

#### Annual summary

minimum  
average  
maximum

7.2  
7.45  
7.6

2  
3.27  
7

2  
2.56  
4

2  
14.25  
48

0  
#DIV/0!  
0

0  
#DIV/0!  
0

**Non-compliance comments:**