

Mid-Coast Council

PO Box 450

Forster NSW 2428

Cooperook Sewage Treatment Plant

Emmo Lane

Cooperook NSW 2426

Environmental Protection licence number: 12583

Licence anniversary date

16th April

Abbreviations-

TSS: Total Suspended Solids

BOD: Biochemical Oxygen Demand

EPA Monitoring Point 2, Discharge Quality Monitoring

Effluent Quality Monitoring Results

Monitoring frequency: monthly

Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms (cfu/100ml)	Oil & Grease (mg/L)	Compliance
7/05/2024	16/May/24	7.1	<2	<2	<2	<10	yes
4/06/2024	18/06/2024	7.1	<2	<2	4	<10	yes
2/07/2024	25/07/2024	7.2	4	5	<2	<5	yes
6/08/2024	19/08/2024	7.3	3	4	26	<5	yes
3/09/2024	13/09/2024	7.3	3	6	18	<5	yes
1/10/2024	17/10/2024	7.2	4	3	~12	<5	yes
5/11/2024	22/11/2024	7.5	5	2.8	4	<5	yes
3/12/2024	19/12/2024	7.4	4	4	5	<5	yes
14/01/2025	21/01/2025	7.3	3	3	2	<5	yes
4/02/2025	20/02/2025	7.3	<2	<2	4	<5	yes
4/03/2025	14/03/2025	7.4	5	3	46	<5	yes
Concentration limits		100%ile	6.5-8.5	30	30	200	10
Annual summary							
	minimum	7.1	3	2.8	2	0	
	average	7.28	3.88	3.85	13.63	#DIV/0!	
	maximum	7.5	5	6	46	0	

Non-compliance comments: