

Mid-Coast Council

PO Box 482

Taree NSW 2430

Lansdowne Sewage Treatment Plant

Off Central Lansdowne Rd

Lansdowne NSW 2426

Environmental Protection licence number: 12586

Licence anniversary date

16th April

Abbreviations-

TSS: Total Suspended Solids

BOD: Biochemical Oxygen Demand

EPA Monitoring Point 2,

Discharge Quality Monitoring

Effluent Quality Monitoring Results

Monitoring frequency: monthly

Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms	Oil & Grease	Compliance
3/05/2022	16/05/2022	7.5	<2	<2	6	<5	yes
7/06/2022	17/06/2022	7.5	<2	2	6	<5	yes
5/07/2022	19/07/2022	7.5	15	4	4	<5	yes
2/08/2022	22/08/2022	7.3	20	4	10	<5	yes
6/09/2022	21/09/2022	7.6	19	10	42	<5	yes
5/10/2022	21/10/2022	7.4	2	3	6	<5	yes
1/11/2022	21/11/2022	7.4	4	3	2	<5	yes
7/12/2022	22/12/2022	7.6	2	3	<1	<5	yes
10/01/2023	24/01/2023	7.5	2	3	~8	<5	yes
7/02/2023	20/02/2023	7.6	4	4	2	<5	yes
7/03/2023	20/03/2023	7.6	3	<2	<2	<5	yes
12/04/2023	21/04/2023	7.4	<2	2	14	<5	yes

Concentration limits

100%ile

6.5-8.5

30

30

200

10

Annual summary

minimum

7.30

2

2

2

<5

average

7.49

7.89

3.80

10.22

<5

maximum

7.6

20

10

42

<5

Non-compliance comments: