Mid-Coast Council

PO Box 482
Taree NSW 2430

Lansdowne Sewage Treatment Plant
Off Central Lansdowne Rd
Lansdowne NSW 2426

Environmental Protection licence number: 12586

Licence anniversary date **16th April**

Abbreviations-
TSS: Total Suspended Solids
BOD: Biochemical Oxygen Demand

EPA Monitoring Point 2,

Discharge Quality Monitoring

Effluent Quality Monitoring Results

Monitoring frequency: monthly

Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms	Oil & Grease	Compliance
7/05/2024	16/05/2024	7.2	<2	3	2	<10	yes
4/06/2024	18/06/2024	7.1	4	3	<4	<10	yes
2/07/2024	12/07/2024	7.1	4	2	12	<5	yes
6/08/2024	27/058/2024	7.3	3	3	6	<5	yes
3/09/2024	13/09/2024	7.4	3	3	<2	<5	yes
Concentration limits	100%ile	6.5-8.5	30	30	200	10	
				Annual summary			
	minimum	7.10	3	2	2	<5	
	average	7.22	3.50	2.80	6.67	<5	
	maximum	7.4	4	3	12	<5	

Non-compliance comments: