

Mid-Coast Council

PO Box 482

Taree NSW 2430

Lansdowne Sewage Treatment Plant

Off Central Lansdowne Rd

Lansdowne NSW 2426

Environmental Protection licence number: 12586

Licence anniversary date

16th April

Abbreviations-

TSS: Total Suspended Solids

BOD: Biochemical Oxygen Demand

EPA Monitoring Point 2,

Discharge Quality Monitoring

Effluent Quality Monitoring Results							
Monitoring frequency: monthly							
Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms	Oil & Grease	Compliance
7/05/2024	16/05/2024	7.2	<2	3	2	<10	yes
4/06/2024	18/06/2024	7.1	4	3	<4	<10	yes
2/07/2024	12/07/2024	7.1	4	2	12	<5	yes
6/08/2024	27/08/2024	7.3	3	3	6	<5	yes
3/09/2024	13/09/2024	7.4	3	3	<2	<5	yes
1/10/2024	17/10/2024	7.2	2	<2	<4	<5	yes
5/11/2024	21/11/2024	7.3	3	2.1	4	<5	yes
3/12/2024	19/12/2024	7.5	2	<2	<1	<5	yes
7/01/2025	17/01/2025	7.5	2		2	<5	yes
14/01/2025	15/01/2025			<2			
4/02/2025	20/02/2025	7.3	2	<2	<2	<5	yes
4/03/2025	14/03/2025	7.4	<2	<2	<1	<5	yes
Concentration limits	100%ile	6.5-8.5	30	30	200	10	
Annual summary							
	minimum	7.10	2	2	2	<5	
	average	7.30	2.78	2.68	5.20	<5	
	maximum	7.5	4	3	12	<5	

Non-compliance comments: