

Mid-Coast Council

PO Box 450

Forster NSW 2428

Cooperook Sewage Treatment Plant

Emmo Lane

Cooperook NSW 2426

Environmental Protection licence number: 12583

Licence anniversary date

16th April

Abbreviations-

TSS: Total Suspended Solids

BOD: Biochemical Oxygen Demand

EPA Monitoring Point 2, Discharge Quality Monitoring

Effluent Quality Monitoring Results

Monitoring frequency: monthly

Date sampled	Date obtained	pH	TSS (mg/L)	BOD (mg/L)	Faecal Coliforms (cfu/100ml)	Oil & Grease (mg/L)	Compliance
7/05/2024	16/May/24	7.1	<2	<2	<2	<10	yes
4/06/2024	18/06/2024	7.1	<2	<2	4	<10	yes
2/07/2024	25/07/2024	7.2	4	5	<2	<5	yes
6/08/2024	19/08/2024	7.3	3	4	26	<5	yes
3/09/2024	13/09/2024	7.3	3	6	18	<5	yes
1/10/2024	17/10/2024	7.2	4	3	~12	<5	yes

Concentration limits	100%ile	6.5-8.5	30	30	200	10	
----------------------	---------	---------	----	----	-----	----	--

Annual summary

minimum	7.1	3	3	4	0
average	7.20	3.50	4.50	16.00	#DIV/0!
maximum	7.3	4	6	26	0

Non-compliance comments: